



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

Date: February 1st, 2018

System No. 3301690

County of Riverside EDA
Attn: Laura Ballesteros
3133 Mission Inn Ave.
Riverside CA, 92507

Enclosed is Citation No. 05_63_18C_002 issued to Twin Pines Boys Ranch public water system. Please note that there are certain deadlines associated with this Citation.

Any person who is aggrieved by a Citation issued by the Riverside County LPA may file a petition with the State Water Resources Control Board (State Water Board) for reconsideration of the Citation. Petitions must be received by the State Water Board within 30 calendar days of the issuance of the Citation. The date of issuance is the date when the Riverside County LPA mails or serves a copy of the Citation, whichever occurs first. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m. Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact this Department at (951) 955-8980

Sincerely,

Daisy Ciudad Real M.P.H., R.E.H.S
Environmental Health Specialist

Certified Mail: 7017 3040 0000 8560 8472



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

**CITATION FOR NONCOMPLIANCE – WATER SYSTEM NO. 3301690
NO. 05_63_18C_002**

Date: February 1st, 2018

Re: Twin Pines Boys Ranch
System No. 3301989

To: County of Riverside EDA
3133 Mission Inn Ave.
Riverside CA, 92507

Section 116650, Article 9, Chapter 4, Part 12, Division 104 of the California Health and Safety Code (H&S Code), authorizes the issuance of a citation for failure to comply with the requirements of the California Safe Drinking Water Act, or any regulation, standard, permit order issued there under.

VIOLATION

The Department of Environmental Health (Department), hereby issues a citation to County of Riverside EDA for the following violations:

Title 22 of the California Code of Regulations (CCR), Section 64432 Specifically, Riverside EDA failed to sample Twin pines Boys Ranch Water System for Inorganic Chemicals between the period of 2014-2017. All public water systems using groundwater shall monitor for Inorganic Chemicals every three years.

Title 22 of the California Code of Regulations (CCR), Section 64449 Specifically, Riverside EDA failed to sample Twin pines Boys Ranch Water System for Secondary Drinking Water Standards between the period of 2014-2017. All public water systems using groundwater shall monitor for Secondary Drinking Water Standards every three years.

CHRONOLOGY OF EVENTS

The water system consist of two wells. The main Well (D&D Rez Well) (Permit #31414) is 1000 feet deep with an 8" casing and is serviced by a submersible pump. There is a backup well (well #1) it is 200ft deep with an 8" casing and is serviced by a submersible pump. The system was last inspected on 9/23/2015. At that time the operator was provided a sampling schedule with dates of when sampling for each well was due. The operator and management

staff was provided a copy of the inspection report on 10/13/2015. The report also included the schedule for sampling with dates of compliance.

RECENT HISTORY

Riverside County EDA failed to sample Twin Pines Boys Ranch for Inorganic and Secondary Drinking Water Standards as required during the period of January 2014- December 2017.

DIRECTIVES

Submit results for Inorganics and Secondary Drinking Water Standard to this Department once you have been notified by the laboratory.

Sample active wells for Inorganics and Secondary Drinking Standards every 3 years and stand-by wells every 9 years. Failure to comply could result in citations with penalty.

This is considered a monitoring and reporting (M&R) violation and requires public notification utilizing the Tier 3 notification method, which is notification to the consumers. All consumers served by this water system must be notified of this violation, as required in Section 64463.4. Attached is a notification form containing the language that is required in Section 64465. The notice must be posted in conspicuous locations throughout the area served by the water system for at least 7 days and included in the 2017 CCR. The posting must be completed by July 1st, 2018. Submit a Proof of Notification to this Department once the notice has been delivered/ posted to your water consumers.

FURTHER ENFORCEMENT ACTION

Failure to comply with this notice and/or failure to comply with Title 22 of the California Code of Regulations may result in an administrative office hearing and assessment of administrative penalties. This Department does not waive any further enforcement action by issuance of this citation.

NOTE:

Samples were collected 1/4/2018- the lab report was submitted to this Department 1/17/2018 all constituents were within standards. The system has returned to compliance.

If you have any questions, please contact this Department at (951) 955-8980



Daisy Ciudad Real, M.P.H., R.E.H.S.
Environmental Health Specialist

Attachments:
Tier 3 Monitoring Notice
Proof of Notification

Certified Mail: 7017 3040 0000 8560 8472